



1250 Gallon - 2 Compartment Tank

CONCRETE PRODUCTS

356 Tuckie Road
N. Windham, CT 06256

(860) 423-4144

FAX (860) 456-1377

PRODUCT CODE
CPST-1250
2 COMPARTMENT

DESIGN NOTES:

- Inlet and outlets have State approved seals.
- Concrete is 5000 psi at 28 days.
- All joints sealed with a butyle rubber sealant.
- Top, bottom, and sides are reinforced with #3 rebar.
- Cover placarded - Danger - Poison Gas - Do Not Enter.

